



**Corporate Office:**

1150 Simpson Way  
Escondido  
California  
92029  
760-466-1060  
760-466-1057 fax  
www.QuakeHOLDIndustrial.com

**Los Angeles Office:**


411 S. Vermont Avenue  
Glendora  
California  
91741  
626-852-8800  
626-852-8801 fax

**San Francisco Bay Area**

**Office:**

22113 Queen Street  
Castro Valley  
California  
94546  
800-959-4053  
510-363-8067 fax

# Flammable Cabinet - Seismic Fastening



**Name:** Flammable Cabinet - Seismic Fastening

**Description:** Strut attached to wall studs - Cabinet attached to strut at 2 locations

**Part Number:** U4.S16.G

**Color:** Gray

**Kit Contains:** Steel strut - 2 safety straps with Industrial Velcro

**Fastening Method:** Steel strut secured to wall studs - Safety straps secured to cabinet with Industrial Velcro

**Strength Ratings:** Each safety strap is rated at 792 pounds shear strength